



Remote Heat Flux Using a Self Calibration Multiwavelength Pyrometer and a Transparent Material

Daniel Ng
Lewis Research Center, Cleveland, Ohio

The NASA STI Program Office . . . in Profile

Since its founding, NASA has been dedicated to the advancement of aeronautics and space science. The NASA Scientific and Technical Information (STI) Program Office plays a key part in helping NASA maintain this important role.

The NASA STI Program Office is operated by Langley Research Center, the Lead Center for NASA's scientific and technical information. The NASA STI Program Office provides access to the NASA STI Database, the largest collection of aeronautical and space science STI in the world. The Program Office is also NASA's institutional mechanism for disseminating the results of its research and development activities. These results are published by NASA in the NASA STI Report Series, which includes the following report types:

- **TECHNICAL PUBLICATION.** Reports of completed research or a major significant phase of research that present the results of NASA programs and include extensive data or theoretical analysis. Includes compilations of significant scientific and technical data and information deemed to be of continuing reference value. NASA's counterpart of peer-reviewed formal professional papers but has less stringent limitations on manuscript length and extent of graphic presentations.
- **TECHNICAL MEMORANDUM.** Scientific and technical findings that are preliminary or of specialized interest, e.g., quick release reports, working papers, and bibliographies that contain minimal annotation. Does not contain extensive analysis.
- **CONTRACTOR REPORT.** Scientific and technical findings by NASA-sponsored contractors and grantees.

- **CONFERENCE PUBLICATION.** Collected papers from scientific and technical conferences, symposia, seminars, or other meetings sponsored or cosponsored by NASA.
- **SPECIAL PUBLICATION.** Scientific, technical, or historical information from NASA programs, projects, and missions, often concerned with subjects having substantial public interest.
- **TECHNICAL TRANSLATION.** English-language translations of foreign scientific and technical material pertinent to NASA's mission.

Specialized services that complement the STI Program Office's diverse offerings include creating custom thesauri, building customized data bases, organizing and publishing research results . . . even providing videos.

For more information about the NASA STI Program Office, see the following:

- Access the NASA STI Program Home Page at <http://www.sti.nasa.gov>
- E-mail your question via the Internet to help@sti.nasa.gov
- Fax your question to the NASA Access Help Desk at (301) 621-0134
- Telephone the NASA Access Help Desk at (301) 621-0390
- Write to:
NASA Access Help Desk
NASA Center for Aerospace Information
7121 Standard Drive
Hanover, MD 21076



Remote Heat Flux Using a Self Calibration Multiwavelength Pyrometer and a Transparent Material

Daniel Ng
Lewis Research Center, Cleveland, Ohio

National Aeronautics and
Space Administration

Lewis Research Center

Available from

NASA Center for Aerospace Information
7121 Standard Drive
Hanover, MD 21076
Price Code: A03

National Technical Information Service
5285 Port Royal Road
Springfield, VA 22100
Price Code: A03

Remote Heat Flux Measurement using a Self Calibration Multiwavelength Pyrometer and a Transparent Material

Daniel Ng
NASA Lewis Research Center

Introduction

A self calibrating multiwavelength pyrometer (Ref. 1) was used to conduct remote heat flux measurements using a transparent sapphire disk by determining the sapphire disk's front and back surface temperatures. Front surface temperature (T_{fs}) was obtained from detection of surface emitted radiation at long wavelengths ($\lambda > 6 \mu\text{m}$). Back surface temperature (T_{bs}) was obtained from short wavelength (1 to 5 μm) radiation transmitted through the sapphire disk. The thermal conductivity κ of the sapphire disk and the heat transfer coefficients h_1 and h_2 of its surfaces are determined experimentally. An analysis of the heat flux measurement is presented.

Method and Experiment

Heat flux sensing is achieved using a sapphire disk and a thin layer of graphite paint deposited on one of the disk's surfaces. The sensor is positioned at the opening of a black body furnace maintained at temperature T_b with the graphite coated surface oriented to receive the radiative and convective heat fluxes from the furnace. The furnace temperature T_b is measured separately by a thermocouple. During the experiment, the multiwavelength pyrometer spectrometer recorded the spectra (Figure 1) of radiation coming through the sapphire sensor in response to the temperature changes of the black body furnace.

Because of the small thickness (two coatings using the application brush) of the graphite paint layer, its temperature is assumed to be the same as that of the sapphire disk surface (T_{bs}) on which the graphite paint is deposited. The thermal conductivity of the sapphire disk is κ . The heat transfer coefficients of the sapphire sensor surfaces are h_1 at the (hotter) surface inside the black body furnace and h_2 at its other (colder) surface. The temperature at distances far away from the front surface is T_∞ .

Short and long wavelength radiation are detected by the heat flux sensor and recorded by the multiwavelength pyrometer. The self calibrating pyrometer described in Ref. 1 is applied to determine the sapphire's back (T_{bs}) and front (T_{fs}) surface temperatures. The availability of several radiation spectra at several different temperatures is crucial to a successful determination of the sapphire surface temperatures without knowing the emissivity and transmissivity of the elements in the optical path of the system.

The following heat flux equations are applicable during heat transfer taking place at the graphite paint interface:

$$\epsilon_b \sigma (T_b^4 - T_{bs}^4) + h_1 (T_b - T_{bs}) = \frac{\kappa}{t} (T_{bs} - T_{fs}) + \int S(\lambda, T_{bs}) d\lambda \quad (1)$$

$$\frac{\kappa}{t} (T_{bs} - T_{fs}) + \int S(\lambda, T_{bs}) d\lambda = \int S(\lambda, T_{bs}) d\lambda + h_2 (T_{fs} - T_\infty) \quad (2)$$

From Eqns. (1) and (2) we obtain by addition and elimination

$$\epsilon_b \sigma (T_b^4 - T_{bs}^4) + h_1 (T_b - T_{bs}) = \int S(\lambda, T_{bs}) d\lambda + h_2 (T_{fs} - T_\infty) \quad (3)$$

In these equations, σ is the Stefan-Boltzman radiation constant, ϵ_b is the graphite paint spectral emissivity, and $t = 6 \text{ mm}$, is the thickness of the sapphire disk. $S(\lambda, T_{bs})$ is the radiation spectrum coming from the graphite paint and τ_λ is the sapphire transmissivity in Eqn (5). The integral $\int S(\lambda, T_{bs}) d\lambda$ in the equations contains the radiative heat flux transmitted through the sapphire disk from the graphite paint surface, and is evaluated from the experimental spectrum numerically. To a very good approximation, the black body furnace emissivity and graphite emissivity are very close to unity, although in the pyrometric determination of temperature from the radiation spectra transmitted through the sapphire disk, the exact values of graphite paint emissivity and the sapphire transmissivity are not necessary.

A commercial spectrometer/radiometer equipped with an indium antimonide/mercury cadmium telluride detector and filter wheel monochromator for radiation from 1.3 to 14.5 μm was used to acquire the spectra in Fig. (1). The self

calibrating feature of the multiwavelength pyrometer eliminated the need to know the graphite emissivity and sapphire transmissivity for temperature determination. For all the spectra in Fig. 1, two wavelengths, $\lambda_1 = 3.878 \mu\text{m}$ and $\lambda_2 = 5 \mu\text{m}$ were selected and the data analyzed according to

$$y(t) = \frac{S(\lambda_1, 0)}{S(\lambda_1, t)} = \frac{\left[\frac{A'(\lambda_2)}{S(\lambda_2, 0)} \frac{c_1}{\lambda_2^5} + 1 \right]^{\frac{\lambda_2}{\lambda_1}} - 1}{\left[\frac{A'(\lambda_2)}{S(\lambda_2, t)} \frac{c_1}{\lambda_2^5} + 1 \right]^{\frac{\lambda_2}{\lambda_1}} - 1} = \frac{\left[A'(\lambda_2) \frac{c_1}{\lambda_2^5} x(\lambda_2, 0) + 1 \right]^{\frac{\lambda_2}{\lambda_1}} - 1}{\left[A'(\lambda_2) \frac{c_1}{\lambda_2^5} x(\lambda_2, t) + 1 \right]^{\frac{\lambda_2}{\lambda_1}} - 1} \quad (4)$$

This equation is obtained from Eqn (12) of Ref. 1, after replacing the quantities $V(\lambda, t)$ and $A(\lambda)$ by $S(\lambda, t)$ and $A'(\lambda)$ in that equation according to

$$S(\lambda, t) = \frac{V(\lambda, t)}{g_\lambda} = \varepsilon_\lambda \tau_\lambda L(\lambda, T(t)) \quad (5)$$

$$A'(\lambda) = \frac{A(\lambda)}{g_\lambda} = \varepsilon_\lambda \tau_\lambda \quad (6)$$

$$x(\lambda_2, t) = \frac{1}{S(\lambda_2, t)} \quad (7)$$

where $S(\lambda, t)$ is the spectrum intensity at wavelength λ at time t when the temperature is $T(t)$, g_λ is the spectrometer calibration constant. $L(\lambda, T(t))$ is Planck's equation defined by:

$$L(\lambda, T(t)) = \frac{c_1}{\lambda^5} \frac{1}{\left(\exp(c_2 / \lambda T(t)) - 1 \right)} \quad (8)$$

c_1 and c_2 are the usual radiation constants. $y(t)$ and $x(t)$ are now the experimentally measured quantities. The quantity $A'(\lambda_2) = \varepsilon_\lambda \tau_\lambda$ is determined from these measured data at wavelengths λ_1 and λ_2 using statistical least square methods. The resulting curve fitting is shown in Fig. 2.

After $A'(\lambda_2)$ is determined, it is used to determine the back surface temperatures $T(t)$ of all the spectra according to

$$T(t) = \frac{c_2 / \lambda_2}{\ln \left(\frac{A'(\lambda_2)}{S(\lambda_2, t)} \frac{c_1}{\lambda_2^5} + 1 \right)} \quad (9)$$

Because sapphire is not transmitting to radiation at wavelength longer than about $6 \mu\text{m}$, the sapphire front surface temperature is determined by fitting a Planck curve of temperature T_{fs} to the radiation spectrum in this region. A constant sapphire emissivity is used in the curve fitting. The result is shown in Fig. (3).

Heat Flux Results

The temperatures of the black body furnace and the sapphire disk front and back temperatures at which the experiments were conducted are:

Table I. Measured Temperatures (K)						
Blackbody	1329.1	1200.8	1079.1	961.9	851.9	746.9
Front Surface	730	645	570	505	455	410
Back Surface	904	776	673	587	516	459

Eqn (1) is transformed into

$$\frac{\epsilon_b \sigma (T_b^4 - T_{bs}^4) - \int S(\lambda, T_{bs}) d\lambda}{(T_b - T_{bs})} = \frac{\kappa (T_{bs} - T_{fs})}{t (T_b - T_{bs})} - h_1 \quad (10)$$

To a good approximation, the emissivity inside the black body furnace and the emissivity of the graphite paint are safely taken to be unity. The quantity on the left hand side is easily calculated because the integral can be evaluated numerically from the measured spectrum. Some error may be introduced in the numerical integration because a triangular approximation estimated the integral from zero wavelength to the shortest wavelength measured (an over estimate), and a truncation occurred after the longest wavelength measurement (an under estimate). The left hand side quantity is plotted against the quantity $(T_{bs} - T_{fs})/(T_b - T_{bs})$. The result is shown in Fig. (4), fitted by a straight line of slope $\kappa/t = 0.105$ and intercept $-h_1 = -0.012$.

Eqn (2) is equivalent to

$$T_{bs} = \left(1 + \frac{h_2}{\kappa/t}\right) T_{fs} - \left(\frac{h_2}{\kappa/t}\right) T_\infty \quad (11)$$

Shown in Fig. (5) is a plot of T_{bs} against T_{fs} giving a straight line, whose slope is $(1 + h_2/(\kappa/t)) = 1.38$, the intercept is $-(h_2/(\kappa/t))T_\infty = -114$. From the intercept and slope, we obtain $T_\infty = 300$ K, which is room temperature. Because κ/t has been determined from Eqn (10), we obtain $h_2 = 0.0399$.

Eqn. (3) is rewritten to provide another estimate of h_1 and h_2

$$\frac{\epsilon \sigma (T_b^4 - T_{bs}^4) + \int \epsilon_\lambda \tau_\lambda L(\lambda, T_{bs}) d\lambda}{(T_b - T_{bs})} = h_2 \frac{(T_{fs} - T_\infty)}{(T_b - T_{bs})} - h_1 \quad (12)$$

The quantity on the right is plotted against $(T_{fs} - T_\infty)/(T_b - T_{bs})$ to produce a straight line (Fig. (6)) of slope $h_2 = 0.038$ and intercept $-h_1 = -0.01$. The heat transfer coefficients h_1 and h_2 are in good agreement with the results determined from Eqn (10) and Eqn (11). From the results of Eqn (10) and Eqn (11), $\kappa = 6 \text{ Wm}^{-1}\text{K}^{-1}$, this is lower than the reported value of 15 to 30 $\text{Wm}^{-1}\text{K}^{-1}$. However the sapphire disk used is slightly yellowish in color.

The measured heat flux (\dot{q}) sensed by the sapphire/graphite paint is the sum of conductive and radiative contributions given by

$$\dot{q} = \frac{\kappa}{t} (T_{bs} - T_{fs}) + \int S(\lambda, T_{bs}) d\lambda \quad (13)$$

The incident heat flux from the black body furnace: $\sigma(T_b^4 - T_{bs}^4) + h_1(T_b - T_{bs})$, the quantity of Eq (13) and radiative heat flux in the experiment are summarized in Table II. The columns represent values at different temperatures. The maximum radiative heat flux contribution is less than 7.5 %.

Table II. Input, Measured and Radiative Heat Flux, (W/cm^2)

Input Heat Flux	18.1	14.0	10.6	7.9	5.9	4.4
Measured Flux	18.8	14.0	10.8	8.5	6.3	5.1
Radiative Flux	1.34	0.78	0.46	0.27	0.17	0.10
Radiative Flux (%)	7.4	5.5	4.3	3.4	2.8	2.3

Conclusion

A remote heat flux sensing is achieved using a transparent sapphire disk coated with a thin graphite layer. The total conductive and radiative heat fluxes were measured. Under the measurement conditions, the dominant component is conductive, with radiation comprising about 7 % of the total heat flux. The ambient temperature, the thermal conductivity of the sapphire disk and the convective heat transfer coefficients of its surfaces were determined.

References

- (1) Ng, Daniel, Self Calibration of a 2-wavelength Pyrometer, NASA/TM—1998-208808, 1998.




Figure 1




Figure 2




Figure 3




Figure 4




Figure 5




Figure 6

REPORT DOCUMENTATION PAGE			Form Approved OMB No. 0704-0188	
Public reporting burden for this collection of information is estimated to average 1 hour per response, including the time for reviewing instructions, searching existing data sources, gathering and maintaining the data needed, and completing and reviewing the collection of information. Send comments regarding this burden estimate or any other aspect of this collection of information, including suggestions for reducing this burden, to Washington Headquarters Services, Directorate for Information Operations and Reports, 1215 Jefferson Davis Highway, Suite 1204, Arlington, VA 22202-4302, and to the Office of Management and Budget, Paperwork Reduction Project (0704-0188), Washington, DC 20503.				
1. AGENCY USE ONLY (Leave blank)		2. REPORT DATE November 1998		3. REPORT TYPE AND DATES COVERED Technical Memorandum
4. TITLE AND SUBTITLE Remote Heat Flux Measurement Using a Self Calibration Multiwavelength Pyrometer and a Transparent Material			5. FUNDING NUMBERS WU-523-21-13-00	
6. AUTHOR(S) Daniel Ng				
7. PERFORMING ORGANIZATION NAME(S) AND ADDRESS(ES) National Aeronautics and Space Administration Lewis Research Center Cleveland, Ohio 44135-3191			8. PERFORMING ORGANIZATION REPORT NUMBER E-11399	
9. SPONSORING/MONITORING AGENCY NAME(S) AND ADDRESS(ES) National Aeronautics and Space Administration Washington, DC 20546-0001			10. SPONSORING/MONITORING AGENCY REPORT NUMBER NASA TM-1998-208809	
11. SUPPLEMENTARY NOTES Responsible person, Daniel Ng, organization code 5510, (216) 433-3638.				
12a. DISTRIBUTION/AVAILABILITY STATEMENT Unclassified - Unlimited Subject Category: 35 This publication is available from the NASA Center for AeroSpace Information, (301) 621-0390.			12b. DISTRIBUTION CODE	
13. ABSTRACT (Maximum 200 words) A self calibrating multiwavelength pyrometer was used to conduct remote heat flux measurements using a transparent sapphire disk by determining the sapphire disk's front and back surface temperatures. Front surface temperature (T_{fs}) was obtained from detection of surface emitted radiation at long wavelengths ($\lambda = 6 \mu m$). Back surface temperature (T_{bs}) was obtained from short wavelength (1 to 5 μm) radiation transmitted through the sapphire disk. The thermal conductivity κ of the sapphire disk and the heat transfer coefficients h_1 and h_2 of its surfaces are determined experimentally. An analysis of the heat flux measurement is presented.				
14. SUBJECT TERMS Heat flux; Pyrometer; Heat flux sensor			15. NUMBER OF PAGES 12	
			16. PRICE CODE A03	
17. SECURITY CLASSIFICATION OF REPORT Unclassified	18. SECURITY CLASSIFICATION OF THIS PAGE Unclassified	19. SECURITY CLASSIFICATION OF ABSTRACT Unclassified	20. LIMITATION OF ABSTRACT	